

5. Batching and mixing of the cement and aggregate may be by volume methods.
6. The casting and vibration method shall provide a dense consolidated concrete.
7. All freshly cast concrete shall be protected from damaging effects of the elements by dry kiln curing.

C. Substitutions:

Any substitutions must be approved in writing ten (10) days prior to bid date, by the architect and/or the engineer of record.

2.03 Fabrication Tolerances

A. Measurements:

1. Overall height and width of units measured at face adjacent to form:
 - 10 ft. or less + 1/8 inch.
 - 10-20 ft. + 1/8 - 3/16
 - 20-30 ft. + 1/8 per 10 feet.
2. Concrete Panel Thickness 1 3/4 inch + 1/4 inch.
 - Side Return Thickness + 3/8 inch - 0 inch.
 - Panel Depth + 3/8 inch - 1/8 inch.

PART 3.00 EXECUTION

3.01 Surface Conditions

A. Inspection:

Prior to installation, inspect work of all other trades. Verify that all such work is complete and accurate to the point where this installation may properly commence in strict accordance with framing shop drawings.

B. Discrepancies:

1. Immediately notify architect of all discrepancies.
2. Do not proceed with installation in areas of discrepancies until such discrepancies have been fully resolved.